



Presentation to American Astronomical Society NGST Town Hall Meeting

Dennis Ebbets on behalf of the TRW/Ball Team January 12, 2000

Outline

- 1. Team experience and contacts
- 2. Overview of the concept
- 3. Technology for the primary mirror
- 4. Estimates of performance
- 5. Comments about the ISIM and SI selection



Our team has experience and capabilities that are important to NGST




- Participation in all of the Great Observatories
 - Hubble Space Telescope (HST)
 - Compton Gamma Ray Observatory (CGRO)
 - Advanced X-ray Astrophysics Facility (Chandra)

1991

- Space Infrared Telescope Facility (SIRTF)
- Cryogenic telescopes and instruments
 - IRAS
 - COBE
 - NICMOS
 - SIRTF
- Large deployable structures
- Lightweight optics, metrology and control














SIRTF 2001

Both companies have participated in NGST studies for many years



Key contacts on the TRW / Ball Team



Program Management

Program Managers - Ralph Schilling, Doug Neam Senior Advisors - Jim Crocker, Greg Davidson Lead Technologist - Paul Lightsey Project Scientist - Dennis Ebbets Program Operations - Doug Au Contract Mgmt - Mike Leonard

Systems Engineering

Cindy Woo Paul Lightsey

- End-to-end architecture
- Interface requirements
- System integration and performance verification planning
- Integrated modeling
- Technology planning
- Risk and trade analysis
- Support to Nexus
- Initial NGST design

Optical Telescope Assembly

Scott Texter Doug Neam

- Definition
- Analyses and modeling
- Technology development
- Interfaces

Integrated Science Instruments Module

Jim Crocker Dennis Ebbets

- System concepts
- Architecture compatibility
- Interfaces
- I&T
- Individual SIs

Ground Segment and Operations

Wendy Watson

- Definition
- Interfaces
- Flight software
- Space/Ground allocations


www.trw.com/ngst www.ballaerospace.com



Our observatory concept is guided by NGST science objectives



Sensitivity for faint targets, angular resolution, image quality wide wavelength range, low backgrounds






Chord fold allows large collecting area & large diameter with precision optical surface




Very good way to stow the Primary Mirror for launch
minimum complexity for 8m Primary Mirror

It is compatible with a variety of mirror technologies

Beryllium segments with active control is an attractive approach







We are developing the technology needed to enable this approach




Subscale Beryllium Mirror Demonstrator



Semi-rigid all Be segment areal density of 9.8 kg/m² ambient and cryo tests completed met optical surface figure goals ambient - cryo figure differences OK demonstrated ROC control interfaces for support and actuators

Cryogenic micro-positioner



Small, lightweight, strong
98mm length, 135gms
20K - 340K temperature range
ambient and cryo tests completed
coarse motion 25mm range, 1µm steps
fine motion 8µm range, 10nm steps

2-2000 AAS NGST




Throughput for visible wavelengths will be influenced by choice of optical coatings



Possibly 9 or more surfaces
Al, Au, Ag options

example:

1 Al + 4 Au + 4 Ag gives good performance






We expect good performance from the sunshield



Passive cooling of OTA to T < 40K and ISIM to T 30K Low MIR background, Zodi limited to > 12µm Durability and long-life performance under study Experience with systems in geo-synchronous orbits is encouraging

Comparison to Yardstick

Identical zodi
Lower thermal emission
cooler sunshield
smaller viewfactors
Longer cross-over






Field of Regard affects operational flexibility and long term scientific productivity



Days of visibility per year



Ecliptic longitude


Sunshield affects Field of Regard
>85° from sun
>15 ° from anti-sun
360 ° roll about sun line
53% of celestial sphere visible

Benefits include:
all targets accessible > half the year
high latitudes accessible > 7 months
long continuous campaigns
revisits for time variability
response to targets of opportunity
scheduling flexibility
retry failed observations



The performance of our design compares favorably to that of the Yardstick






Sensitivity NMS v 2.5 point source images t = 1 hour R = 5 S/N = 5zodi = ecliptic pole

DRM Completion Time

DRM v 2.2 NMS MET v 2.5 Yardstick = 2.8 yrs TRW/Ball = 1.6 yrs




1-12-2000 AAS NGST



Our architecture is compatible with a Yardstick like suite of science instruments







Concluding Remarks



We think we have a viable concept that is responsive to the scientific and programmatic priorities of NGST

Our approach is "MIR Compatible"

We have considerable flexibility for ISIM accommodation
We have been participating in SI and ISIM studies
We are following the selection process with interest

We solicit dialogue and inputs from the community